

Rapporto/Report No. K 2617 2019 B2

Decreto 7 Novembre 2017, n. 186
Certificazione ambientale del generatore di calore

Model:
ZVB20-AUTO / ZVB20-PA

Produttore / Manufacturer:
AMG S.p.A.

Marchio commerciale / Trademark:
CENTROMETAL

This report may only be published and forwarded to third parties in its complete, unabridged form. The publication or dissemination of extracts, summaries, appraisals or any other adaptation and alterations, in particular for advertising purposes, is only permissible with the prior written permission of TÜV Rheinland.
Publication of page 2 is permitted.

Decreto 7 Novembre 2017, n. 186
Certificazione ambientale del generatore di calore

Produttore / Manufacturer: **AMG S.p.A**
Via delle Arti e dei Mestieri, 1/3
I-36030 San Vito di Leguzzano (VI)

Marchio commerciale / Trademark: **CENTROMETAL**

Modello / Model: **ZVB20-AUTO / ZVB20-PA**

Tipologia prodotto / Product type: Caldaia a pellets / Wood pellet boiler

Norma di riferimento / Reference standard: DIN EN 303-5:2012

Ente Notificato CPR/ Notified body acc. CPR: NB 2456

Rapporto di Prova di riferimento / Reference test report: K 2617 2019 Z1

Potenza termica nominale / Nominal heat output: 17,5 kW

Combustibile di prova / Test fuel: Pellet di legna / wood pellet

Prestazioni del generatore di calore Performances of the heating appliance		Classi di prestazione / Performance classes			
		5 stelle	4 stelle	3 stelle	2 stelle
PP⁽¹⁾ mg/Nm³	4,8	10	15	20	40
COT⁽¹⁾ mg/Nm³	2,1	5	10	15	20
NOx⁽¹⁾ mg/Nm³	126,6	120	130	145	200
CO⁽²⁾ mg/Nm³	14,0	25	100	250	300
η⁽²⁾ %	92,1	92	91	90	90
⁽¹⁾ Determinato applicando il metodo di misura della CEN/TS 15883 <i>Determined applying the measurement method of the CEN/TS 15883</i>					
⁽²⁾ Determinato secondo la EN 303-5:2012 <i>Determined according to EN 303-5:2012</i>					
Nota: tutti i valori di concentrazione calcolati al 13% di O ₂ in condizioni normali (273 K, 1013 mbar, gas secco) <i>Note: all the concentration values are calculated at 13% of O₂ in normal conditions (273 K, 1013 mbar, dry gas)</i>					


Sulla base delle prestazioni indicate, il generatore di calore risulta in classe
Based on the declared performances, the heating appliance is in class
4 stelle / 4 stars

Cologne, 10.05.2019
432 / mc

TÜV Rheinland Energy GmbH
Test Centre for Energy Appliances
NB 2456 (CPR)
DIN EN ISO/IEC 17025:2005
accreditation: D-PL-11120-04-00

Assessor:

Report released after review:


Dipl.-Ing. M. Ciccarelli


Dipl.-Ing. M. Reimbold